



मुर्तिजापूर नगर परिषद मुर्तिजापूर

जिल्हा अकोला

momurtizapur1@gmail.com



क्रमांक/नपमु/मु.अ./आ.वि./ ९८३/२०२२

दिनांक : ९/९/२०२२

To,
Principal,
Academic Heights Public School
Hirpur Road Murtizapur

FIRE SAFETY CERTIFICATE

It is certified that the School Building of Academic Heights Public School Murtizapur situated on Gat No. 45, at MaujeMurtizapur, Taluka Murtizapur Dist. Akola comprising of ground and first floors occupied by Academic Heights Public School Murtizapur have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified by the officers concerned of Fire Service on 29/08/2022 in the presence of Mrs. Laxmi Pramanik, Principal Academic Heights Public School Murtizapur and that the building/premises is fit for occupancy class I to XII with effect from 29/08/2022 for a period of 01 years in accordance with rule and subject to compliance of the conditions.

Issued on at Murtizapur by

मु.अ.पी.प. ५९३
९/९/२०२२

मुर्तिजापूर नगर पालीका
मुर्तिजापूर, जि. अकोला


Chief Officer
Municipal Council Murtizapur


Principal
Academic Heights Public School
Murtizapur

POSH-Sexual Harassment of Women in Workplace Committee
for 2025-26

Sr.No	Name	Designation	Phone Number
1	Mr.Khushal Thanvi	Principal (Chair-Person)	9151513838
2	Mr.Saurabh Kumar	TGT/PGT/Member	8403936187
3	Mrs.Rakhi Pinjarkar	Counsellor	7773990005
4	Mr.Anirban Chatterji	TGT/PGT/Member	8927223256
5	Mr.Devanshu Davare	TGT/PGT/Member	7620718931
6	Mr.Chandraprakash Gulhane	PRT/Member	7620507623
7	Miss Anushka Pandey	Student Representative/Member (Student)	7058734457
8	Mst.Sarvesh Thakare	Student Representative/Member (Student)	9403285037



MOB : 758875 7881 - 9623879510

Office : 0724 - 242 1887

Email ID : ali_bandukwala@rediffmail.com

Maharashtra Fire Services Licence No: MFS-LA/RF-368

GST TIN NO : 27AUJPA0585H1ZD

SSI REG.NO : MH02A0001862

BANDUKWALA & COMPANY

C/O. POST BOX NO. 24, TAJNAPETH, MOHAMMED ALI ROAD, AKOLA (MS)
Fire Extinguishers ◊ Fire Alarm & Detectors ◊ Safety Products ◊ Maintenance

FORM (A)

See Section 2(3) and Rule (1)

CERTIFICATE FROM THE LICENSED AGENCY REGARDING THE COMPLIANCE OF THE FIRE PREVENTION AND LIFE SAFETY MEASURES

CERTIFICATE

Certified that I/We have executed the works toward compliance in relation to Fire Prevention and Life Safety Measures to be provided and performed other related activities required to be carried out, in the following building or premises As required under the Provision of the Maharashtra Fire Prevention and Life Safety Act, 2006 [Mah.iii of 2007]

Description and Location of building Premises are as under

ACADEMIC HEIGHTS PUBLIC SCHOOL
SURVEY NO.45 HIRPUR ROAD,
MURTUZAPUR,
DIST. AKOLA

The detail of the work and related activities which, I/We have executed or performed are mentioned in the ANNEXURE I as Attached

WITH BEST REGARDS

FOR: BANDUKWALA & CO.

BANDUKWALA & CO.

Proprietor

WHEN IT COME'S TO SAFETY THINK OF US



MOB : 758875 7861 - 9623879610

Office : 0724 -- 242 1887

Email ID : ali_bandukwala@rediffmail.com

Maharashtra Fire Services Licence No: MFS-LA/RF-368

GST TIN - NO : 27AJUPA0525H1ZD

SSI REG NO : MH02A0001662

BANDUKWALA & COMPANY

C/O. POST BOX NO. 24, TAJNAPETH, MOHAMMED ALI ROAD, AKOLA (MS)
Fire Extinguishers ◊ Fire Alarm & Detectors ◊ Safety Products ◊ Maintenance

ANNEXURE I

THE FOLLOWING FIRE FIGHTING EQUIPMENTS, ARE INSTALLED IN THE
ACADEMIC HEIGHTS PUBLIC SCHOOL
SURVEY NO.45 HIRPUR ROAD,
MURTUZAPUR,
DIST. AKOLA

Following List of Material are Installed & Tested Successfully

Sr. No	DESCRIPTION	CAPACITY	QTY
01	ABC (STORE PRESSURE) TYPE FIRE EXTINGUISHER	06 KGS	16
02	CARBON DI OXIDE (CO ₂)TYPE FIRE EXTINGUISHER	4.5 KGS	04
03	HOSE REEL DRUM SET WITH 30 MTR HOSE PIPE	30 MTS	08
04	FIRE BUCKET CAPACITY 9 LTS	9 LTS	04
05	WET RISER 100 NB DIAMETER	---	01
06	HYDRANT VALVE 63 MM (AS PER IS SPECIFICATION)	----	06
07	YARD HYDRANT 63 MM (AS PER IS SPECIFICATION)	---	02
08	HOSE BOX COMPLETE WITH 15 MTR CANCAS PIPE	----	08
09	MAIN ELECTRIC PUMP 3 PHASE 10 HP, 35 Mts HEAD	----	01
10	STAND BY ELECTRIC PUMP 3 PHASE 7.5 HP, 43.5 Mts HEAD	----	01
11	ELECTRICAL AUTO START FIRE CONTROL PANEL FOR PUMP (AS PER IS SPECIFICATION)	---	01
12	FIRE SERVICE INLET	---	01

WITH BEST REGARDS

FOR: BANDUKWALA & CO.

BANDUKWALA & CO.

Proprietor

WHEN IT COME'S TO SAFETY THINK OF US